



OFFICE OF THE GENERAL MANAGER,
WATCO DIVISION-I, BHUBANESWAR.

E-mail: - gmdivonewatco@gmail.com



Letter No. 5689 / Dated 14/7/2025

To

The Principal,
Apeejay School,
P.O- Ghatikia, Near Durga Mandap,
Bhubaneswar-751003

Sub: Renewal of Safe Drinking Water & Sanitation Certificate.


Ref:- Letter No. APJBBSR/090/2025-26 Dt.01.07.2025.

Sir,

I am sending herewith the test report of drinking water samples duly tested in M/S Spectro Analytical Lab Pvt. Ltd. As requested by you.

Encl: As above.

Yours faithfully


14/7/25
General Manager
WATCO Division-I
Bhubaneswar
WATCO Division-I, Bhubaneswar



ATANU RATH
PRINCIPAL
APEEJAY SCHOOL BHUBANESWAR
GHATIKIA NEAR DURGA MANDAP
PIN-751003
Affiliation No.-1530307


14/7/2025

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

5689

Dated:

14/7/2025

It is certified that an inspection team headed by Basant Kumar Belwara
 (Name of Officers with designation) from G.M. WATCO Division I BBSR
 (Name of Department/ Office) inspected the General Manager WATCO Division I BBSR
 (Name & Address of the school) on 14/7/2025 (date of inspection) and found that
 the Apeejay School BBSR (Name of school) has safe drinking water facilities
 for the students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
 The above is valid for a period of one year.

Signature with Seal: del G. 14/7/25
General Manager
WATCO, Division-I.....

Name

Basant Kumar Belwara

Designation

General Manager

Name & Address of the Office / Department :

To

The principal
Apeejay School
Ghatikia BBSR
 (Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.

par
ATANU RATH
PRINCIPAL
APEEJAY SCHOOL BHUBANESWAR
GHATIKIA NEAR DURGA MANDAP
PIN-751003
Affiliation No.-1530307

Under PPP Mode, Govt. of Odisha.

TEST REPORT

Customer Name & Address: M/s APEEJAY SCHOOL BHUBANESWAR At- Ghatikia, Near Durga Mandap, Bhubaneswar, Odisha, Pin- 751003.	Test Report No.: STB03072025/0532
Contact Person: Mr. LaxmiDhar Behera.	Contact No.: 9090859064
E.mail ID: laxmi.behera@apeejayschool.in	Date of Sample Receipt: 03.07.2025
Type of Sample (Source) : Drinking Water (Aquaguard)	Sample Quantity (Received): 3 Ltr.
Sampling Location: At- APEEJAY SCHOOL Campus, Ghatikia.	Date of Start of Testing: 03.07.2025
Sample Condition: Good	Date of Completion of Test: 04.07.2025
Sample Submitted at Laboratory By: Customer	Test Report Issue Date: 05.07.2025
Special Instruction (If Any): No	Sample ID: STB250703/0532
Customer reference No. & Date: As per Contract.	

1. (Chemical Testing – Water)

TEST RESULTS

Sr. No.	TEST PARAMETERS	TEST METHODS	OBSERVED RESULTS	Limits Max. (as per IS 10500)	
				Acceptable Limit	Permissible Limit in the Absence of Alternate Source
1	pH , at 25 °C	IS 3025 (Pt-11), 2022	6.43	6.5 - 8.5	No relaxation
2	Conductivity (µS/cm), at 25 °C	IS 3025 (Pt-14) 2013, RA-2023	195.2	NA	NA
3	Turbidity (NTU)	IS 3025 (Pt-10) ,2023	1.16	1 NTU	5 NTU
4	Total Dissolved Solids (mg/l), at 180 °C	IS 3025 (Pt-16), 2023	121	500 mg/l	2000 mg/l
5	Total Alkalinity (as CaCO ₃), (mg/l)	IS 3025 (Pt-23) ,2023	75	200 mg/l	600 mg/l
6	Total Hardness (as CaCO ₃), (mg/l)	IS 3025 (Pt-21) 2009, RA - 2023	90	200 mg/l	600 mg/l
7	Calcium (as Ca), mg/l	IS 3025 (Pt-40),2024 (Cl.5)	23.44	75 mg/l	200 mg/l
8	Magnesium (as Mg), mg/l	APHA 24 th Edition 3500-Mg (B),2023	7.65	30 mg/l	100 mg/l
9	Chlorides (as Cl ⁻), mg/l	IS 3025 (Pt-32) 1988, (Cl. 2) , RA -2019	9.49	250 mg/l	1000 mg/l
10	Odour	IS 3025 (Pt-5) 2018	Agreeable	Agreeable	Agreeable
11	Taste	IS 3025 (Pt-8) ,2023	Agreeable	Agreeable	Agreeable
12	Sodium (as Na), mg/l	IS 3025 (Pt-45) , 2024 (Cl. 5)	5.7	NA	NA
13	Potassium (as K), mg/l	IS 3025 (Pt-45) , 2024 (Cl. 5)	2.1	NA	NA
14	Colour, (CU)	APHA 24 th Edition 2120 (C) ,2023	4.51	5 HU	15 HU
15	Iron (as Fe), mg/l	IS 3025 (Pt-53) ,2024 (Cl. 6)	0.66	1.0 mg/l	No relaxation
16	Nitrate (as NO ₃), mg/l	APHA 24 th Edition 4500 N - NO ₃ ⁻ (B),2023	5.16	45 mg/l	No relaxation
17	Fluoride (as F ⁻), mg/l	APHA 24 th Edition 4500 F ⁻ (D),2023	*BDL	1.0 mg/l	1.5 mg/l
18	Sulphate (as SO ₄ ²⁻), mg/l	IS 3025 (Pt-24/Sec1) (Cl.5), 2022	10.54	200 mg/l	400 mg/l

Note: *BDL-Below Detection Limit (Fluoride -Detection Limit is 0.05 mg/l)

- Remarks:**
1. Test results are related to the sample submitted by the customer only.
 2. Test report refers to the values obtained at the time of testing & results are related to the sample tested as above under the stated condition.
 3. The report shall not be reproduced in part / full without written consent of the laboratory.

----- End of Report -----

parit

ATANU RATH
PRINCIPAL
APEEJAY SCHOOL BHUBANESWAR
GHATIKIA NEAR DURGA MANDAP
PIN-751003
Affiliation No.-1530307


Reviewed & Authorized By
(Madhusudan Rath, TMC Chemical)

Under PPP Mode, Govt. of Odisha.

TEST REPORT

Customer Name & Address: M/s APEEJAY SCHOOL BHUBANESWAR At- Ghatikia, Near Durga Mandap, Bhubaneswar, Odisha, PIN- 751003	ULR No.: NA
Contact Person: Mr. LaxmiDhar Behera	Test Report No.: STB03072025/0532
E.mail ID: laxmi.behera@apeejayschool.in	Contact No.: 9090859064
Type of Sample (Source) : Drinking Water (Aquaguard)	Date of Sample Receipt: 03.07.2025
Sampling Location: At- APEEJAY SCHOOL Campus, Ghatikia	Sample Quantity (Received): 500 ML
Sample Condition: Good	Date of Start of Testing: 03.07.2025
Sample Submitted at Laboratory By: Customer	Date of Completion of Test: 04.07.2025
Special Instruction (If Any): No	Test Report Issue Date: 05.07.2025
Customer reference No. & Date: As per Contract.	Sample ID: STB250703/0532

1. (Biological Testing – Water)

TEST RESULTS

Sr. No.	TEST PARAMETERS	TEST METHODS	OBSERVED RESULTS	Limits Max. (as per IS 10500)
				Acceptable Limit
1	Total Coliform (CFU/100 ml)	IS 15185	< 1 CFU	Absent /100ml
2	E.coli (CFU/100 ml)	IS 15185	< 1 CFU	Absent /100 ml

[NOTE- <1: Not detected in 100ml]

- Remarks:**
1. Test results are related to the sample submitted by the customer only.
 2. Test report refers to the values obtained at the time of testing & results are related to the sample tested as above under the stated condition.
 3. The report shall not be reproduced in part / full without written consent of the laboratory.

----- End of Report -----

par

ATANU RATH
PRINCIPAL
APEEJAY SCHOOL BHUBANESWAR
GHATIKIA NEAR DURGA MANDAP
PIN-751003
Affiliation No.-1530307

